

**Core:- 44mm CF240 High Density Core**

**Configuration:- Pair**

**Action:- Single Action**

**Vision Panel:- NA**

**UKAS Test House :- SRL Technical Services Limited**

**Certificate Number:- C/21290/R01**


**Test Number:- 028**

**Acoustic Rating:-  $R_w$  30dB**

**Please Note:-**

Drawings are for indication of acoustic's only not fire, the correct configuration of fire seals must be added to achieve the required fire rating for the core.


**Above drawings are indicative only**



## Test Number 28

**Test Number :** 28      **Air temperature:** 19.1 °C  
**Client:** Midland Building Products Ltd      **Air humidity:** 65 %  
**Test Date:** 12/08/2010      **Receiving room volume** 300 m3  
**Sample height:** 1.975 m      **Source room volume:** 115 m3  
**Sample width:** 0.886 m      **Sample weight:** 23.5 kg/m2  
**Product** Pair Premdor 44mm  
**Identification:** FAS 35 perimeter seal  
 FAS 45 Automatic drop-down seal  
 FAS Single action meeting stile seal

Freq f Hz	Sound Reduction Index, dB	
	1/3 Oct	1/1 Oct
50+	16.7	
63+	23.6	19.0
80+	19.2	
100	21.5	
125	27.1	24.1
160	25.8	
200	24.3	
250	27.1	26.5
315	29.6	
400	30.2	
500	30.8	30.6
630	30.7	
800	28.7	
1000	27.4	28.2
1250	28.6	
1600	29.6	
2000	30.9	30.9
2500	32.7	
3150	33.1	
4000	33.7	33.5
5000	33.5	
6300+	36.9	
8000+	38.1	38.2
10000+	40.0	
Average 100-3150	28.6	Version v1.7



Rating according to BS EN ISO 717-1:1997  
**Rw(C;Ctr)= 30 ( 0;-1) dB**

\* shows measurement corrected for background  
 # shows limit of measurement due to background  
 + shows frequency beyond standard and not UKAS accredited